



Manitowoc Public Utilities

Generation Resiliency Project

Presentation of Findings and Recommendations
To
City Council, City of Manitowoc

May 18, 2020

Prepared by



Community Owned... Customer Focused

Manitowoc Public Utilities

&



BLACK & VEATCH



Outline of Presentation

- Introduction
- Overview of the Existing System
- Generation Resiliency Options
- Electric Distribution System Energized (Resiliency)
- Conclusions of the Studies
- Project Financing
- MPU Commission Recommendations
- Questions/Discussion



Team Members

- MPU Staff
 - Nilaksh Kothari: CEO & General Manager
 - Cindy Carter: Senior Manager - Business Services
 - Don Duenkel: Senior Manager - Utility Operations
 - Andy Onesti: Senior Manager - Technical Services

- Consultants
 - Dick Sterken: Black & Veatch
 - Marcus Chandrapal: Black & Veatch
 - Mike Borgstadt: Burns & McDonnell
 - Dave Seitz.: TRC Consulting
 - Larry Becker: Frontier Consulting



OVERVIEW OF EXISTING SYSTEM

- Vision/Goals/Strategic Focus of MPU
 - Facts in Brief
 - Sources of Capacity
 - ATC/MPU Transmission Interconnections
 - Electric Industry Changes and Challenges
 - Summary of Existing System
-



Vision/Goals/Strategic Focus of MPU

MISSION

MPU is committed to be the trusted primary resource for providing customer-focused utility services.

VISION

To be a thriving and innovative regional utility service provider that exceeds customer expectations.



Strategic Focus of Electric Utility

Goal

- Maintain best in class operations and focus on continuous improvement to provide safe, reliable, and efficient utility services.

Objective

- Implement improvements of electric facilities to increase reliability (resiliency) and customer classification.



Facts in Brief-2019

- Annual Energy Sales: 518,927 MWH (retail)
133,206 MWH (wholesale)
 - Annual Steam Sales 210,000 klbs
 - Annual Peak Demand 99.6 MW
 - Electric Substations
 - Lakefront
 - Dewey Street
 - **Custer Street**
 - Northeast
 - **Rapids**
 - Revere Street
 - **Mirro (Supplies Skana only)**
 - Distribution System
 - 250 Miles Overhead and Underground Wires
 - 13,200 Volts and 4,160 Volts (limited to a portion of downtown)
 - Retail Electric Utility Revenues \$ 41 million
-



Sources of Capacity (2004 versus 2020)

| Sources of Capacity - | 2004 | 2020 |
|-------------------------------------|--------------------|--------------------|
| - Steam Generating Plant | 70.0 MW | 77.0 MW |
| - Diesel | 11.0 MW | 0.0 MW |
| - Combustion Turbine (Gas) | 22.0 MW | 22.0 MW |
| - Market Purchases | 20.0 MW | 10.0 MW |
| Age of Facilities / Capacity | | |
| - Boiler #5 | 50 Years / 15.0 MW | Retired |
| - Boiler #6 | 46 Years / 17.5 MW | Retired |
| - Boiler #7 | 38 Years / 17.5 MW | Retired |
| - Boiler #8 | 14 Years / 21.0 MW | 30 Years / 21.0 MW |
| - Boiler #9 | --- | 16 Years / 63.4 MW |
| - Diesel | 11.0 MW | Retired |
| - Combustion Turbine (Refurbished) | 22.0 MW | 41 Years / 22.0 MW |
| - Steam Turbine Generator #2 | --- | Retired |
| - Steam Turbine Generator #3 | --- | Retired |
| - Steam Turbine Generator #4 | 51 Years | Retired |
| - Steam Turbine Generator #5 | 46 Years | 62 Years |
| - Steam Turbine Generator #6 | 38 Years | Retired in-place |
| - Steam Turbine Generator #9 | --- | 16 Years |

Note: Diesel units used to start Boilers 5, 6, 7 & 8 in the event of a transmission system outage.




Electric Industry Changes & Challenges

- In the last decade dramatic changes in electric industry:
 - More wind and solar generation, i.e. intermittent power generation
 - Several nuclear and fossil fuel (coal) power plants shut down
 - New base load generation is almost exclusively using natural gas
 - Other challenges include:
 - Boilers 8 & 9 dependent on transmission power to start up & operate
 - Climate change risks more natural disasters like tornados, flooding, etc.
 - Increase in cyber attacks
 - Distributed generation
 - Battery storage
 - Electric Vehicles
 - All of the above increase risks:
 - Instability and reliability of transmission grid
-

A Major Transmission Failure - City Area With Power



Manitowoc Public Utilities





Summary - Existing Condition

- MPU historically has added and removed generating assets for more than 100 years depending on the needs and life of the equipment
 - There are three interconnections between ATC & MPU
 - In the last decade dramatic changes in electric industry with i.e. intermittent power generation such as wind and solar has potentially resulted in:
 - A decrease in stability and reliability of transmission grid
 - MPU's inability to start boilers and provide power to city
 - MPU Commission concerned on the consequences of a major transmission system failure which include:
 - MPU has no back-up power to start boilers 8 and 9
 - Loss of water pressure may cause boil water advisory
 - Loss of Wastewater Treatment and Lift Stations
 - General concern of public health and safety
 - August 2003 black out in eastern U.S. and Canada lasted more than 5 days
-



GENERATION RESILIENCY

- Summary of Planning and Engineering Studies
 - Risk Assessment Findings
 - Options Evaluated
 - Costs
 - Summary of Studies
-



Burns & McDonnell Study - 2013

- MPU Commission authorized multiple studies from 2013- 2019
 - Burns & McDonnell retained to perform a Condition Assessment of Power Generation Facilities.
 - Conclusions of the Study:
 - Confirmed Boiler 8 and 9 need power supply within 15 – 30 minutes to avoid plugging loop seal. Unplugging the loop seal may take several days.
 - Diesel #2 not adequate to start Boiler 8 or Boiler 9 and keeping it operational long term not feasible
 - Infrastructure is not in place to use the Custer CT to start Boiler 8 or Boiler 9
 - New fast start generation is best option to start Boiler 8 or 9
-



Black & Veatch Study - 2015-2016

- Black & Veatch retained in 2015 to follow up on conclusions of previous study.
- Objectives of the Study:
 - Conduct high level risk assessment of disasters
 - Confirm the size of the generating unit required to start boiler(s)
 - Assess technologies for the new generating unit
 - Cost estimates of the proposed options
 - Present findings to MPU Commission




RISK ASSESSMENT

- Renewable Resources
 - Natural & Man-Made Disasters
 - Summary
-

RENEWABLE ENERGY GROWTH – RISK AREAS

Renewable electricity generation by fuel type in the AEO2015 Reference case
billion kilowatthours



Source: U.S. Energy Information Administration (April 2015).

IMPACTS OF RENEWABLE ENERGY

- Renewable targets of 30-50% in some states are likely to be problematic for transmission grid stability.
- Most of the renewable growth is from non-dispatchable sources (Wind and Solar)
- Because they are non-dispatchable these sources supplement base load generation (hydro, natural/gas, nuclear, and coal)
- Grid instability increases.

RISK ASSESSMENT

- **Natural Disasters**
 - Tornado
 - Intense Wind Storm
 - Floods
 - Blizzard / Ice Storms
 - Lightning Strike
- **Man-made Disasters**
 - Cyber Attack
 - Fire at Power Plant
 - Chlorine gas leak
 - Human Failure

SUMMARY OF DISASTERS

Following are MPU vulnerabilities from disasters

- A tornado or intense wind storm can knock out transmission system
- An ice storm can knock out above ground transmission system
- A cyber attack may or may not impact transmission or generation at MPU
- A lightning strike will most likely result in loss of generation
- A chlorine gas leak should not cause loss of power

SUMMARY OF RISK ASSESSMENT

- MPU is dependent upon the grid for restoration of power to Boilers 8 & 9
- Renewable energy resources has resulted in grid instability
- Impacts of an **extended** outage can be severe
 - J-valve solidification disabling boilers for 3 to 5 days
 - Customer Health and Safety (Loss of power for food refrigeration, normal health care services, traffic control normal police services etc.)
 - Loss of Water Distribution System Pressure
- *City of Manitowoc, as confirmed by County, does not have enough shelter facilities with back-up power generation.*



Generation Reliability Enhancement

- ATC meeting September 22, 2016:
 - Cannot guarantee power into Manitowoc in 30 minutes or less
 - Confirm funding is not available for ATC/MISO for a fast start unit for MPU
 - ATC will allow MPU distribution system to be isolated from transmission grid with approval
- MPU needs to provide power to City of Manitowoc without ATC transmission line loop around the city.



OPTIONS ASSESSED

- Various Technologies Assessed
 - Various Sites Assessed
 - Cost Estimates at Alternative Sites
-



Options Assessed

- Following technologies were assessed:
 - Single Combustion Turbine (CT)
 - Single Reciprocating Internal Combustion Engine (RICE)
 - Multiple Reciprocating Engines
 - Express sub-transmission line from Custer CT to Columbus Street Power Plant

- Following sites were assessed:
 - Columbus Street near Power Plant
 - Lakefront across from WWTP
 - District Heat Site on South 7th Street



Cost Estimates of Options

| | CAPITAL COST | NPV |
|---|--------------|----------------|
| 1 - Existing Columbus Street Plant | \$16,990,000 | (\$6,299,262) |
| 2a - Lakefront Location #1 OH TL | \$35,796,411 | (\$26,630,269) |
| 2b - Lakefront Location #1 UG TL | \$36,282,560 | (\$27,155,821) |
| 3a - Downtown District Heat OH TL | \$35,105,944 | (\$25,883,826) |
| 3b - Downtown District Heat UG TL | \$35,430,044 | (\$26,234,202) |
| 4a - 8 th St. Substation OH TL | \$34,460,717 | (\$25,186,293) |
| 4b - 8 th St. Substation UG TL | \$34,703,792 | (\$25,449,069) |
| 5a - Custer to Columbus AG T-Line | \$6,812,960 | (\$7,365,274) |
| 5b - Custer to Columbus UG T-Line | \$9,045,280 | (\$9,778,558) |



Conclusions of the Study

- Columbus Street generation plant is important for local electricity reliability and a part of a system that people need and depend on 24/7.
 - MPU is dependent upon the grid for restoration of power.
 - Impacts of an extended outage can be severe.
 - New generation to start boilers 8 & 9 is required when transmission service to the MPU territory is lost.
 - 10-12 MW generator to start B9 with ID fan, PA fan, and Feed pumps with soft-start conversion.
 - 8 MW generator needed for restart of Boiler 8.
 - The various technologies and sites were evaluated.
 - Benefit of supplementary power generating capacity – Water Plant & CBCWA water delivery; avoidance of capacity market purchases.
-



Conclusions of the Study - (Cont'd)

- Plant upgrades for island operation (micro-grid) include Generator 5 Excitation and Governor, Turbine 9 Governor, and Plant Tie Transformer Relaying
- A diesel and/or natural gas Reciprocating Internal Combustion Engine (RICE) will be the low cost option
- The estimated construction cost depending on technology varies from \$ 17 to \$35 million
- Custer Street (CT) express line to Power Plant does not have the lowest Net Present Value.
- Issues to be addressed: cost, emissions, permitting issues.

Black and Veatch Study – 2018

- October 2018 – Objectives of the Study
 - Assess the two selected RICE options:
 - Gray Market Wärtsilä Model 12V50DF: 1 unit, in new building
 - New Jenbacher JGC 620: 4 units, containerized
 - Locate either option at south end of Columbus Street Power Plant
 - Perform a detailed construction cost estimate
 - Perform a 20 year Net Present Value analysis of the two options
 - List Pros and Cons of each option

CAPITAL COSTS OF TWO SELECTED ALTERNATIVES

| CAPITAL COST ESTIMATE SUMMARY | | |
|-------------------------------|----------------------------------|-----------------------------------|
| ITEM DESCRIPTION | OPTION 1: WÄRTSILÄ TOTAL COST | OPTION 2: JENBACHER TOTAL COST |
| Civil/Structural | \$ 1,401,693 | \$ 836,726 |
| Mechanical/Piping | \$ 8,501,838 | \$ 12,274,202 |
| Electrical/Controls | \$ 1,129,170 | \$ 1,417,242 |
| Direct Total | \$ 11,032,701 | \$ 14,528,170 |
| Indirects | | |
| Engineering | \$ 1,560,000 | \$ 1,950,000 |
| Construction Management | \$ 551,635 | \$ 726,408 |
| Start-up & Commissioning | \$ 257,400 | \$ 400,400 |
| Subtotal | \$ 13,401,736 | \$ 17,604,978 |
| Contingency | \$ 1,340,264 | \$ 1,760,322 |
| Grand Total | \$ 14,742,000 | \$ 19,365,300 |

GENERATION OPTIONS SUMMARY

| Option | Capital Cost | NPV | Advantages/Disadvantages |
|---|-----------------|----------------|---|
| 1 – One Wärtsilä Model 12V50DF – unused and Gray Market | \$14,742,000.00 | (\$13,067,000) | <p>Advantages:</p> <ul style="list-style-type: none"> • Lower NPV • Higher thermal efficiency: less fuel, lower operating cost • Full generation capacity on both primary and secondary fuel <p>Disadvantages:</p> <ul style="list-style-type: none"> • Requires an SCR |
| 2 – Four Jenbacher JGC 620 | \$19,365,300.00 | (\$14,232,000) | <p>Advantages:</p> <ul style="list-style-type: none"> • May not require an SCR • Start-up time will be less for the smaller gensets <p>Disadvantages:</p> <ul style="list-style-type: none"> • Derate on secondary fuel: 6.86MW at full capacity on propane |



Additional Project Cost Estimates

- Additional improvements needed at the Power Plant:
 - Steam By-Pass for B8 & B9 and other plant modifications required for Black Start = \$1,833,000
 - New 13.8kV and 480V Black Start buses = \$850,000
 - Equipment only cost for New Soft Starters on B9 ID & PA fan, B8 FD fan = \$353,000
 - Allowance for demo/modifications to existing plant for VFD space and cable removal = \$50,000
 - Indirect Costs (Contingency, Engineering) = \$1,389,000
- TOTAL ESTIMATED COSTS = \$4,475,000 - \$5,200,000



Conclusions of Resiliency Generation

- Generation with Gray Market Wärtsilä of 11.3 MW is the preferred option – lowest NPV.
 - Wärtsilä provides a dual fuel option - natural gas and diesel fuel.
 - The estimated construction cost is approximately \$15 million.
 - The generating unit will meet the following objectives:
 - Boiler 8 and 9 can continue to operate if dispatched
 - Following facilities will have power within 2 hours:
 - Water Treatment Plant/Wastewater Treatment Plant
 - City Fire and Police
 - County Jail & Dispatch Center
 - Additional modifications required at the Power Plant for \$5.0 million.
 - Total project cost estimated at \$20 million.
-



ELECTRIC DISTRIBUTION SYSTEM ENERGIZED/RESILIENCY

- Objectives
 - City Areas Energized
 - Summary
-




Objectives

- Since 1963-64 MPU distribution has been connected to the regional electric transmission system
- Identify what areas of the City can and cannot be served in the event of a transmission system outage
- Identify areas that can be served based on availability of different generation resources
- Identify any areas of the City that cannot be served without the transmission system even if most generation is available


City Areas - Energized

- 11.3 MW (RICE) Generation only operating



City Areas - Energized (Cont'd)


- RICE + Custer CT





City Areas - Energized (Cont'd)


- RICE + B8/B9 + Custer CT





City Areas - Energized (Cont'd)

- RICE + CT + B8/B9 + SUBTRANSMISSION EXPRESS LINE
- No Power to SKANA





Summary - Distribution Resiliency

- A large portion of City can be energized without 69 kV transmission line with MPU electric distribution system intact.
 - A sub-transmission line will be required from Power Plant Substation to Revere Substation at an estimated cost of \$2 million with contingency to energize the NE part of the City, except SKANA.
 - The objective is to first power those facilities that are important to health and safety within 2-4 hours of a major power outage.
 - The remainder of City will have power within 16-24 hours of a major power outage.
-



Manitowoc Public Utilities

A large, faded version of the MPU logo is centered on the page, serving as a watermark. It features the letters 'MPU' in a light red font, with blue and yellow wavy lines and a lightning bolt below them, all enclosed in a light red oval border.

CONCLUSIONS OF THE STUDY



Conclusions of the Study

- Fast Start Generating Capability of 11.3 MW at Columbus Street Plant provides:
 - Ability to power large portion of City without 69 KV
 - Maintain Steam Customers
 - Ability to operate Water and Waste Water Facilities
 - Support Customer Health and Safety
 - Protect Power Plant Assets
 - Wärtsilä Engine from Tote are apparent best option:
 - Lowest NPV
 - Ability to provide full power on secondary fuel (function in the event of a Natural Gas outage)
 - A sub-transmission line from Power Plant to Revere Substation
 - The total project cost for resiliency of generation and electric distribution is estimated at \$22 million.
-



PROJECT FINANCING

- Project Financing
- Rate Impact



Project Financing

- The project has been in planning since 2013
- The project is expected to be operational in Fall 2022 or Spring 2023.
- The total project cost is not to exceed \$22 million which includes:
 - An 11.3 MW Wartsila engine generation - \$15 million
 - Modifications at the Power Plant - \$5 million
 - A subtransmission line from Lakefront Substation to Revere Substation - \$2 million
- No borrowing is required for the project as MPU Commission has been planning for this major capital improvement



Rate Impact

- History of Rate Adjustments
 - May 2009: -4.0%
 - July 2014: -2.0%
 - October 2016: -3.5%
 - May 2020: -5.5%
 - The projected rate increase in 2023 is between 0.0% - 3.0% depending on the following:
 - Energy prices in the market
 - Capacity price offset from market purchase
 - MPU payment of PILOT to City increases by approximately \$350,000 in 2023 annually.
-



Manitowoc Public Utilities

A large, faded version of the MPU logo is centered on the page, serving as a watermark. It features the letters "MPU" in a light red color, with the same blue and yellow wavy lines and lightning bolt below them, all enclosed in a light red oval.

**MPU COMMISSION
RECOMMENDATION TO
CITY COUNCIL**



Action Plan

- The 11.3 MW boiler project will take 24-36 months, depending on the time it takes to obtain PSC and DNR permits
- Steps to be taken during the next 12 months include:
 - Submit filings with PSCW and WDNR to support construction of the project
 - Evaluate quotations received and negotiate contracts contingent on PSC/DNR approval
 - File a MISO/ATC generation-transmission interconnect agreement and obtain approval
 - Complete detailed engineering and bid the project



MPU Commission Recommendation

- MPU Commission unanimously approved proceeding with the expansion of the local generating facility with 11.3 MW boiler project.
- MPU Commission is recommending that the Finance Committee and City Council approve the project for up to \$22 million for resiliency of generation and electric distribution system.



Manitowoc Public Utilities

A large, faded version of the MPU logo is centered on the page, serving as a watermark. It features the letters "MPU" in a light red color, with the blue wavy water and yellow lightning bolt graphic below it, all contained within a light red oval border.

QUESTIONS/DISCUSSION
