

1900

City of Manitowoc Department of Public Works  
EMERGENCY SEWER CALL REPORT

DATE 2/24/20 TIME 2:15 a.m./p.m. DAY OF WEEK SU  M TU W TH F S

CALLER Lusier Plumbing PHONE \_\_\_\_\_

ADDRESS 1317 Grand Ave RECEIVED BY JJ Walkood

COMPLAINT NATURE Basement backup

US/DS ID 3-14 / 3-11 CREW Brad B/Brad L. EQUIPMENT #53

DATE & TIME WORK ASSIGNED 2/24/20 2:15 a.m./p.m.

ARRIVED 2:30 a.m./p.m. DEPARTED 3 a.m./p.m.

ACTION TAKEN:  JETTED  RODDED  FLUSHED  OTHER \_\_\_\_\_

SEWER MAIN OBSTRUCTED  YES  NO (IF YES, CHECK CAUSE(S) OF BLOCKAGE BELOW)

- UNKNOWN  SOLIDS  BROKEN LATERAL  DISPOSABLE DIAPER
- ROOTS  GREASE  TAMPONS  TOWELING/TP/ETC.
- SOAP SCALE  SLUDGE  OTHER \_\_\_\_\_

OCCUPANT CONTACTED  YES  NO BY Chad IF NOT, WHY \_\_\_\_\_

LIST ANY DAMAGES Entire basement wet with sewage  
Looked to be 1"-2" deep

COMMENTS & RECOMMENDATIONS

CREW COMMENTS: \_\_\_\_\_

CREW SIGNATURE Brad Boma

SUPERVISOR ON SITE  YES  NO IF NOT, WHY \_\_\_\_\_

SUPERVISOR COMMENTS Over main was not flowing when we  
arrived. We jetted and opened the main. Basement receded  
according to plumber.

SUPERVISOR SIGNATURE [Signature]