

Ordinance
Manitowoc Municipal Code
Chapter 25

Section 25.060 (2)(k)

Motion to amend to read as follows:

Section 1. Section 25.060 (2)(k) is amended to read as follows:

“(2) General Discharge Prohibitions. In addition to the prohibitions and limitations in MMC 25.040(1)(g) and (h), the following substances shall not be introduced into the wastewater disposal system or otherwise to the facilities of the City:

(k) Any wastewater containing an average molybdenum concentration of greater than ~~0.10~~ 0.17 mg/l, unless the industry discharge permit allows for a different concentration level or a molybdenum mass loading of 0.10 lb./day, except that wastewater exceeding the concentration limit is permitted if the mass loading of molybdenum is less than 0.10 lb./day. Measurements shall be taken over a 24-hour period or over the period of discharge, if such a discharge is less than 24 hours.”

1st Mike Howe

2nd Dan Koski

Vote: 7-0