

COW  
5-15-17

17-0515

**ORDINANCE**

An Ordinance to revise Section 17.090 of the Manitowoc Municipal Code regulating lead water services.

The Mayor and Common Council of the City of Manitowoc do ordain as follows:

**Section 1.** Section 17.090 (3) is created to read as follows:

**“17.090. Additional Requirements**

**(3) Water Services and Private Water Mains Construction Materials.** Water service laterals and private water mains from the public water main in the street to the curb stop shall be of ductile iron, PVC, PE or of Type K copper materials, as set forth in Wis. Adm. Code SPS Chapter 384.

When it appears that a lead or galvanized water service has failed, it shall be replaced with ductile iron, PVC, PE or of Type K copper, from the main in the street to the curb stop; provided, however, that water services damaged by the water utility during disconnection for nonpayment or a water bill may be repaired rather than replaced.

When it appears, upon inspection, that a lead or galvanized water service lateral has failed from the curb stop to the building control valve, the lateral shall be replaced by a lateral of materials as set forth in Wis. Adm. Code SPS Chapter 384.”

**Section 2.** This Ordinance shall take effect the day after publication.

Introduced           MAY 15 2017           \_\_\_\_\_

Adopted \_\_\_\_\_

Approved \_\_\_\_\_

\_\_\_\_\_  
Justin M. Nickels, Mayor

This instrument drafted by Kathleen M. McDaniel, City Attorney

**Fiscal Impact:** n/a  
**Funding Source:** Costs to be paid by MPU and property owners  
**Finance Director Approval:** /sc  
**Approved as to form:** /kmm