RESOLUTION

WHEREAS, City of Manitowoc deems it desirable to install an ornamental lighting system to illuminate the Popp's Subdivision Development, and

WHEREAS, Municipal Code 12.150(2)(a) defines ornamental street lighting as a type of lamp that is mounted to a standard or post to which energy is supplied from an underground electrical distribution system or from fixtures of special ornamental design, and

WHEREAS, Municipal Code 12.150(2)(b) provides that the Common Council may, by resolution, without petition, provide for the installation of an ornamental lighting system, and

WHEREAS, Municipal Code 12.150(2)(c) provides that the installation cost may be paid by the property owners or by the City at its discretion, and

WHEREAS, the Manitowoc Public Utilities estimates the annual street lighting expense charged to the City for this section of roadway will increase by \$238.08, and

WHEREAS, Municipal Code 12.150(2)(d) provides that the operation and maintenance expenses of the ornamental street lighting system are to be paid from the City's general fund to the Manitowoc Public Utilities according to rates approved and on file with the Wisconsin Public Service Commission, and

WHEREAS, Manitowoc Public Utilities recommends installing four (4) each, 45-Watt, Coach, ornamental, LED street lighting standards to provide lighting consistent with ANSI RP-8, American National Standard Practice for Roadway Lighting,

NOW THEREFORE BE IT RESOLVED BY THE MAYOR AND COMMON COUNCIL OF THE CITY OF MANITOWOC, that Manitowoc Public Utilities install and maintain four (4) each, 45-Watt, Coach, ornamental LED street light standards in the Popp's Subdivision Development.

Introduced			
Adopted			
Approved			
	Justin M. Nickels, Mayor		

Fiscal Impact: Anticipated an annual operating expense of \$238.08 for the four ornamental street lights. Installation costs to be the responsibility of the property owner(s). No additional tax levy or 2025 budget amendments needed.

Funding Source: General Fund (1100-32500-522200)

Finance Director Approval: /SMA

Approved as to Form: /EGN

This resolution was drafted by Brandon Davitz, Electrical Engineer, Manitowoc Public Utilities