State of Wisconsin
DEPARTMENT OF NATURAL RESOURCES
101 S. Webster Street
Box 7921
Madison Wi 53707-7921

Tony Evers, Governor Preston D. Cole, Secretary Telephone 608-266-2621 Toll Free 1-888-936-7463 TTY Access via relay - 711



October 15, 2020

DEBORAH NEUSER CLERK CITY OF MANITOWOC 900 QUAY ST MANITOWOC WI 54220 Project Number: PWSID#: DNR Region: County:

W-2020-0850 43603648 NER Manitowoc

WATER MAIN PLAN AND SPECIFICATION APPROVAL

The Wisconsin Department of Natural Resources, Division of Environmental Management, Bureau of Drinking Water and Groundwater, is conditionally approving plans and specifications for the following project. An engineering report or information of sufficient detail to meet the requirements of s. NR 811.09(3), Wis. Adm. Code, was submitted along with the plans and specifications.

Water system name: Manitowoc Waterworks

Date received: 09/11/2020

Engineering firm: Manitowoc Public Utilities Professional Engineer: Robert D. Michaelson, P.E.

DNR Plan Reviewer: McCrea Baker, 101 South Webster Street, Madison, WI 53703, (608) 279-8426,

mccrea.baker@wisconsin.gov

Location(s): Watermain replacement on Menasha Avenue

Private water mains and water services may require plan review by Department of Safety and Professional Services (DSPS), and are not reviewed or approved by the Department of Natural Resources. Contact DSPS at 608-267-9421 for further information on potential need for plan review.

Water main specifications submitted with this project for the City of Manitowoc were reviewed, are hereby approved, and will remain on file with the Department under approval W-2020-0850 dated October 15, 2020.

Condition(s) of approval:

- A resident project representative shall be designated by the water supply owner or by the agent retained
 by the owner. The resident project representative shall be knowledgeable regarding the proposed
 construction and be able to ensure the improvements are being constructed in accordance with the
 department approved plans, specifications, and conditions of the approval. The project representative
 shall be present on the work site as need to assure proper construction and installation of the
 improvements. (s. NR 811.11, Wis. Adm. Code)
- 2. After construction, maintenance, repair or modification, waterworks facilities shall be disinfected by procedure outlined in the applicable A.W.W.A. standards for wells, water mains, storage facilities or treatment facilities. Waterworks may not be placed in service until bacteriological samples have established that the water is bacteriologically safe. (s. NR 810.09(4), Wis. Adm. Code)



Project Number: W-2020-0850 Page 2

Approval constraints: The project was reviewed in accordance with s. 281.41, Wis. Stats. for compliance with Chapters NR 108, NR 810 and NR 811, Wis. Adm. Code and is hereby approved in accordance with s. 281.41, Wis. Stats. subject to the conditions listed above. This approval is valid for four years from the date of approval.

Appeal rights: If you believe that you have a right to challenge this decision, you should know that the Wisconsin Statutes and administrative rules establish time periods within which requests to review Department decisions must be filed. To request a contested case hearing pursuant to s. 227.42, Wis. Stats., you have 30 days after the decision is mailed, or otherwise served by the Department, to serve a petition for hearing on the Secretary of the Department of Natural Resources. Requests for contested case hearings must be made in accordance with ch. NR 2, Wis. Adm. Code. Filing a request for a contested case hearing does not extend the 30 day period for filing a petition for judicial review. For judicial review of a decision pursuant to ss. 227.52 and 227.53, Wis. Stats., you must file your petition with the appropriate circuit court and serve the petition on the Department within 30 days after the decision is mailed. A petition for judicial review must name the Department of Natural Resources as the respondent.

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES

For the Secretary

James K. Witthuhn, P.E.

amer K. La Fitt

Public Water Engineering Section

Bureau of Drinking Water and Groundwater

Project Plan Reviewer

McCrea Baker

Public Water Engineering Section

Bureau of Drinking Water and Groundwater

cc: Robert D. Michaelson, P.E. - Manitowoc Public Utilities, City (by email)